

§419.35

by the following factors to calculate the maximum for any one day and maximum average of daily values for thirty consecutive days.

(1) Size factor.

1,000 bbl of feedstock per stream day	Size factor
Less than 24.9	0.73
25.0 to 49.9	0.76
50.0 to 74.9	0.83
75.0 to 99.9	0.91
100.0 to 124.9	0.99
125.0 to 149.9	1.08
150.0 or greater	1.13

(2) Process factor.

Process configuration	Process factor
Less than 4.49	0.73
4.5 to 5.49	0.80
5.5 to 5.99	0.91
6.0 to 6.49	0.99
6.5 to 6.99	1.08
7.0 to 7.49	1.17
7.5 to 7.99	1.28
8.0 to 8.49	1.39
8.5 to 8.99	1.51
9.0 to 9.49	1.65
9.5 or greater	1.72

(3) See the comprehensive example in subpart D, §419.42(b)(3).

(c) The provisions of §419.14(c) apply to discharges of process wastewater pollutants attributable to ballast water by a point source subject to the provisions of this subpart.

(d) The quantity and quality of pollutants or pollutant properties controlled by this paragraph, attributable to once-through cooling water, are excluded from the discharge allowed by paragraph (b) of this section.

(e) *Effluent limitations for contaminated runoff.* The following effluent limitations constitute the quantity and quality of pollutants or pollutant properties controlled by this paragraph and attributable to contaminated runoff which may be discharged after the application of the best conventional pollutant control technology by a point source subject to this subpart.

(1) If wastewater consists solely of contaminated runoff and is not commingled or treated with process wastewater, it may be discharged if it does not exceed 15 mg/l oil and grease based upon an analysis of any single grab or composite sample.

(2) If contaminated runoff is commingled or treated with process waste-

40 CFR Ch. I (7-1-08 Edition)

water, or if wastewater consisting solely of contaminated runoff which exceeds 15 mg/l oil and grease is not commingled or treated with any other type of wastewater, the quantity of pollutants discharged shall not exceed the quantity determined by multiplying the flow of contaminated runoff as determined by the permit writer times the concentrations listed in the following table:

Pollutant or pollutant property	BCT effluent limitations for contaminated runoff	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
	Metric units (kilograms per 1,000 m ³ of flow)	
BOD ₅	48.	26.
TSS	33.	21.
Oil and grease	15.	8.
pH	(¹)	(¹)
	English units (pounds per 1,000 gallons of flow)	
BOD ₅	0.40	0.22
TSS	0.28	0.18
Oil and grease	0.13	0.067
pH	(¹)	(¹)

¹ Within the range of 6.0 to 9.0.

[50 FR 28526, July 12, 1985]

§419.35 Pretreatment standards for existing sources (PSES).

Except as provided in 40 CFR 403.7 and 403.13 any existing source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for existing sources (PSES). The following standards apply to the total refinery flow contribution to the POTW:

Pollutant or pollutant property	Pretreatment standards maximum for any 1 day
	(Milligrams per liter (mg/l))
Oil and grease	100
Ammonia (as N)	1100

¹ Where the discharge to the POTW consists solely of sour waters, the owner or operator has the option of complying with this limit or the daily maximum mass limitation for ammonia set forth in §419.33 (a) and (b).